



To: All Prospective Bidders

From: Purchasing Department

Date: September 13, 2019

Subject: Inquiries and Responses

RFP/ITB#: 110-2019 Demo of Existing Reclaim Water Sand Filters & Install of Puroflux Filter and Control Systems Including Backwash Holding Tank

Inquiries and Responses:

1. Please confirm that the existing housekeeping pad currently in use under the (2) sand filters will need to be extended for the (1) new sand filter and (1) new holding tank. Dimensions should be no less than 6" outside of the outer edge of the equipment while maintaining factory suggested clearances, with a finished edge at 45*. **The comment or scope is correct. The existing housekeeping pad currently in use under the (2) sand filters will need to be extended for the (1) new sand filter and (1) new holding tank. Dimensions should be no less than 6" outside of the outer edge of the equipment while maintaining factory suggested clearances, with a finished edge at 45***