



35



1. REMOVE AND SALVAGE EXISTING PERFORATED METAL CEILING AND SUPPORTS, MECHANICAL DUCT, AND LIGHTING BELOW EXISTING GWB UPPER CEILING. EXISTING FIRE SPRINKLER LINES TO REMAIN. CONTRACTOR TO SURVEY AND DOCUMENT ROUTING PRIOR TO REMOVAL.

SALVAGE PLAN




MCC MEETING ROOM 71501

ASK-1

TUCK-HINTON
ARCHITECTURE & DESIGN

22004
04/25/22



2. DEMOLISH EXISTING GWB CEILING AND SUPPORTING METAL FRAMING. EXISTING BUILDING SYSTEMS ABOVE GWB CEILING TO REMAIN.

3. INSTALL NEW METAL FRAMING AS DESIGNED, SEE STRUCTURAL SKETCHES AND TWO LAYERS OF 5/8" GWB AT PREVIOUS HEIGHT. FINISH TO EXISTING VERTICAL GWB AND PAINT BLACK.

DEMOLITION AND NEW CONSTRUCTION

16' 8' 0 16'




MCC MEETING ROOM 71501

ASK-2

TUCK-HINTON
ARCHITECTURE & DESIGN


22004
04/25/22

35



4. REINSTALL SALVAGED MECHANICAL DUCT WORK, LIGHTING, AND PERFORATED METAL CEILING AT PREVIOUS HEIGHT

FINISHED PLAN



MCC MEETING ROOM 71501

ASK-3

TUCK-HINTON
ARCHITECTURE & DESIGN


22004
04/25/22

SITE VISIT PHOTOGRAPHS

PROJECT: Music City Center – Level 7 Meeting Room Ceiling
LOCATION: Nashville, Tennessee
DATE: January 20 and April 1, 2022



Photograph 1 – MEP above Architectural Ceiling



Photograph 2 – Architectural Ceiling

SITE VISIT PHOTOGRAPHS

PROJECT: Music City Center – Level 7 Meeting Room Ceiling
LOCATION: Nashville, Tennessee
DATE: January 20 and April 1, 2022



Photograph 3 – Gypsum Ceiling above MEP and Architectural Ceiling



Photograph 4 – Sagging Ceiling Grid System

SITE VISIT PHOTOGRAPHS

PROJECT: Music City Center – Level 7 Meeting Room Ceiling
LOCATION: Nashville, Tennessee
DATE: January 20 and April 1, 2022



Photograph 5 – Sagging Ceiling Grid System



Photograph 6 – Sagging Ceiling Grid System

SITE VISIT PHOTOGRAPHS

PROJECT: Music City Center – Level 7 Meeting Room Ceiling
LOCATION: Nashville, Tennessee
DATE: January 20 and April 1, 2022



Photograph 7 – Sagging Ceiling Grid System



Photograph 8 – Light Gauge Support Framing Bearing on Piping

SITE VISIT PHOTOGRAPHS

PROJECT: Music City Center – Level 7 Meeting Room Ceiling
LOCATION: Nashville, Tennessee
DATE: January 20 and April 1, 2022




Photograph 9 – Rotated Light Gauge Support Framing



Photograph 10 – Bowing Light Gauge Support Framing

NOTES:
 1.) COLD FORMED FRAMING IS UNPUNCHED
 2.) EXISTING WALL FRAMING SIZE, GAUGE, AND SPACING IS UNKNOWN
 REMOVE 12" TALL X 48" WIDE SECTION OF DRYWALL TO VERIFY FRAMING. DESIGN IS BASED ON 6" (16ga) STUD SPA @ 16" c/c.
 3.) ADJUST OPERABLE WALL BOLTS AFTER CEILING INSTALLATION.




PLAN

SUBJECT MCC
LVL 7 MIB Room CEILING
FOR _____ BY BAT



SHEET NO. 2 OF 8
JOB NO. 22303
DATE 4/9/2022



SECTION 1

SUBJECT MCC
LVL 7 MTO ROOM CEILING
FOR BY BAT

RBA STRUCTURAL ENGINEERING, LLC
A Subsidiary of Ross Bryan Associates, Inc.

SHEET NO. 3 OF 8
JOB NO. 273303
DATE 4/7/2022

1000T125-54 (50ksi)
CONT.

10" COLD FORMED
JOIST (SEE PLAN)



(12) #12 TEK
SCREENS

(1) #12 TEK SCREEN
TYP. @ JOIST
TOP & BOTTOM
FLANGE

400S137-54 (60ksi)
AT EACH EXISTING
STUD

600T125-54 (50ksi)
CONT
(TOP & BOTTOM)


600S162-54
(50ksi)
SPA @ 16" c/c MAX

(2) 600T125-54 (50ksi)
BETWEEN EACH
EXISTING HORIZ MEMBER

(2) HILTI X-U
MX STEEL NAILS
AT 16" c/c MAX

EXISTING
DRYWALL &
FRAMING
ENCLOSURE AT
W14x61 BEAM
TO REMAIN


SECTION 2



SUBJECT MCC
LVL 7 MIG ROOM CEILING
FOR _____ BY BAT




SHEET NO. 4 OF 8
JOB NO. 223303
DATE 4/7/2022



SUBJECT MCC
LVL 7 MTG ROOM CEILING
FOR _____ BY BAT



SHEET NO. 5 OF 8
JOB NO. 773033
DATE 4/7/2022




SECTION 4

SUBJECT MCC
LVL 7 MTG ROOM CEILING
FOR _____ BY BAT



SHEET NO. 6 OF 8
JOB NO. 223303
DATE 4/7/2022




SECTION 5


SUBJECT MCC
LVL FMB ROOM CEILING
FOR _____ BY BAT

RBA STRUCTURAL ENGINEERING, LLC
A Subsidiary of Ross Bryan Associates, Inc.

SHEET NO. 7 OF 8
JOB NO. 223303
DATE 4/19/2022



DETAIL A



DETAIL B

SUBJECT MCC
LVL 7 MTA ROOM CEILING
FOR _____ BY BAT



SHEET NO. 8 OF 8
JOB NO. 223303
DATE 4/19/2022

